

PROJECT TITLE: **COMPLEX VILLAS AT STREET-45, PLOT-01, AL-AIN**

Client
H.H Sheikha Wadima Bint Saeed Bin
Shakhboot Al Nahyan

Consultant
WORLD PLANNERS
WPC CONSULTANT ENGINEERS

Contractor
Commodore Contracting Co. LLC

MATERIAL APPROVAL REQUEST

MAR No. MAR/1085

Material Description:

Revision No. 0

LIGHT FITTINGS - MOSQUE

Date: 04-02-2016

Material Trade Name:
ELMARK, VIOKEF

Listed Proposed

Manufacturer / Supplier:
Simpsons Switchgear Industries FZCO
P.O.Box 263184, Dubai, U.A.E.
T:04-8867881, F:04-8867882

Country of Origin:
EUROPE REGEIONS

Contract Specification
Details:
N/A

Technical Specifications:
Part-B, Section-12.

Discipline:
EL

Location / Area of Use:

Mosque

Technical Details of proposed materials:

Attachments :-

1 Specification Comparison Sheet Yes N/A
2 Samples submitted Yes N/A
3 Original Brochure Yes N/A

4 Other Supporting Documents attached (if any)

Notes / Comments:

For CONTRACTOR:

Name: **TALAL JARBOU**

Signature: 

Designation: **Senior Projects Manager**

EMPLOYER / ENGINEER Approval Status / Comments

Approval Code- (A)

Approval Code- (B)

Approval Code- (C)

Approval Code- (D)

Approved

Approved with Comments

Incorporate Comments,
Revise and Resubmit

Not Approved

Comments: -

*fine attached comments on
attached letter.*

Name:

st. elec eng

Signature: 

Date: *17-02-2016*

Designation:

Form No.: WPC/MAR/R0/230810



WORLD PLANNER CONSULTANT ENGINEERS

COMMENT SHEET

Project Name: Residential Complex for H.H. Sheikha Wadima Bint Said Bin Shakbout Al Nahyan - Al Ain, Asharej, Street No. 45, Plot No. 01

Description: Light Fittings - Mosque

MAR Ref.: MAR – 1085, Rev-00

Date: 04 February 2016

Approval Status: "C" Revise & Resubmit

COMMENTS:

Contractor shall comply with below –not limited to– comments:

- Proposed Fixture's Specification is not matching with the attached catalogue.
- All Light Fitting shall be as per List of material
- Lux Calculation should be rectified with the right height of working plan and lux level as per standard.
- The Valid Commercial license shall be submitted.
- Sample of each Light Fixture shall be submitted since the proposed spec is different than project specs.
- Technical catalogue, origin certificate, test certificates shall be submitted.
- Nos. of the light fitting should be matched with the Lux studies.
- Approved ceiling layout shall be attached.

Regards,

